

June 05, 2025

Addendum No. 01

File Reference Number: RFP 2025 032

Title: Cochrane Diesel Shop – Oil Storage Room Upgrades

RE: Clarifications/Questions

Please refer to the following information / clarifications:

Item 1: Would ONTC accept Equals for the following:

Specified Tag	Base of Design	Base Model	Our Equal	Equal Model
RHC-1	Thermolec	CACNT0P6ICB1AAX6M KDAST	Neptronic	DHCI00H
MD-1 & MD-2	Tamco	9000	Alumavent	3961
N/A	EH Price	610	Nailor	51SH-O
N/A	EH Price	630	Nailor	5145H-O

Answer: Please find below the list of approved equals and the comments provided:

Specified Tag	Base of Design	Base Model	Our Equal	Equal Model	ONTC
RHC-1	Thermolec	CACNT0P6ICB1AAX6M KDAST	Neptronic	DHCI00H	Not Approved
MD-1 & MD-2	Tamco	9000	Alumavent	3961	Not Approved
N/A	EH Price	610	Nailor	51SH-O	Approved
N/A	EH Price	630	Nailor	5145H-O	Approved

Comments:

- Nailor for the grilles is acceptable.
- Control damper to remain as TAMCO 9000 series opposed blade.
- Heater to remain as Thermolec, 304 S.S. Heater with 304 S.S. Tubular elements.

This Addendum hereby forms part of the RFP.

Regards,

Brinda Ranpura
Procurement Contracts Specialist
brinda.ranpura@ontarionorthland.ca