

July 11, 2025

Addendum No. 03

File Reference Number: RFP 2025 026

Title: North Bay Motor Coach Services Parking Lot Upgrades

RE: Clarifications/Questions

CLARIFICATIONS/QUESTIONS

Item 1: Are all the fence posts, top rails, gates, and hardware to be black?

Answer: Yes.

Item 2: Are the two (2) openings in the fence for snow removal going to have double 4.5 meter gates making the opening a total width of nine (9) meters when both gates are open?

Answer: Each side of the snow removal gates will have single opening and will be 4.5 meter wide.

Item 3: Part 5 – Request for Proposals – CCDC 2 – 2020 Supplementary Conditions – Section 57 GC 11.1 Insurance

Would ONTC agree to delete clauses 57.3.6 – Professional Liability Insurance and 57.3.7 – Technology Liability Insurance?

Answer: Yes, these clauses will be removed from the final agreement.

This Addendum hereby forms part of the RFP.

Regards,

Brinda Ranpura
Procurement Contracts Specialist
brinda.ranpura@ontarionorthland.ca