



555 Oak Street East  
North Bay, Ontario  
P1B 8L3

555, rue Oak Est  
North Bay (Ontario)  
P1B 8L3

Tel: 1-800-363-7512  
[www.ontarionorthland.ca](http://www.ontarionorthland.ca)

**January 08, 2026**

**Addendum No. 02**

**File Reference Number: RFP 2025 115**

**Title: North Bay Wheelshop Exhaust and Ventilation Upgrade**

**RE: Clarifications/Questions**

---

**QUESTIONS/CLARIFICATIONS:**

**Item 1:** Will ONTC consider Johnson Controls LP as an approved alternate vendor for Wheelshop Exhaust and Ventilation Upgrade project?

**Answer:** ONTC is unable to add Johnson Controls Canada LP as an alternate vendor for the Wheelshop Exhaust and Ventilation Upgrade project. As only a few control points are being added for the dampers, introducing a new system from a different manufacturer would be disadvantageous to ONTC.

This Addendum hereby forms part of the RFP.

Regards,

Brinda Ranpura  
Procurement Contracts Specialist  
[brinda.ranpura@ontarionorthland.ca](mailto:brinda.ranpura@ontarionorthland.ca)